



Evaluation Listing CCMC 13244-L

MASTERFORMAT: 07 21 19.02
Issued: 2006-06-21
Re-evaluated: 2010-06-21
Revised: 2010-09-30
Re-evaluation due: 2012-06-21

Airmetic[®] SOYA, Heatlok[®] SOYA, Polar Foam SOYA

1. Evaluation

Conforms to CAN/ULC-S705.1-01 (including Amendments 1 and 2), Type 2.

For retrofit constructions, time before occupancy is one (1) day.

2. Description

A Type 2, spray-applied rigid polyurethane foam of medium density. The foam system consists of two components: “A100” or “A1004” isocyanate and a polyurethane resin identified as “B02230/B02400/PF73000” for “Airmetic[®] SOYA, Heatlok[®] SOYA, Polar Foam SOYA,” respectively. The two components are mixed on site by a qualified installer with fixed-ratio positive displacement equipment.

The final cured product for “Airmetic[®] SOYA, Heatlok[®] SOYA” is green.
The final cured product for “Polar Foam SOYA” is peach.

3. Standard and Regulatory Information

Canadian Urethane Foam Contractors Association (CUFCA) has been identified by Demilec Inc. as the third-party organization that operates the field quality assurance program (FQAP) for “Airmetic[®] SOYA, Heatlok[®] SOYA, Polar Foam SOYA” in accordance with CAN/ULC-S705.2-05.

CUFCA can be contacted at: (866) 467-7729 or 1-866-GO-SPRAY.

See the Preface and the standard for explanation.

Listing Holder: Demilec Inc.
870, Curé-Boivin
Boisbriand, QC J7G 2A7
Tel: 450-437-0123
Fax: 450-437-2338

Plant(s): Boisbriand, QC

This Listing is issued by the Canadian Construction Materials Centre, a program of the Institute for Research in Construction at the National Research Council of Canada. The Listing must be read in the context of the entire CCMC Registry of Product Evaluations.

Readers must confirm that the Listing is current and has not been withdrawn or superseded by a later issue. Please refer to <http://www.nrc-cnrc.gc.ca/eng/services/irc/ccmc.html>, or contact the Canadian Construction Materials Centre, Institute for Research in Construction, National Research Council of Canada, 1200 Montreal Road, Ottawa, Ontario, K1A 0R6. Telephone (613) 993-6189. Fax (613) 952-0268.

NRC has evaluated the material, product, system or service described herein only for those characteristics stated herein. The information and opinions in this Listing are directed to those who have the appropriate degree of experience to use and apply its contents. This Listing is provided without representation, warranty, or guarantee of any kind, expressed, or implied, and the National Research Council of Canada (NRC) provides no endorsement for any evaluated material, product, system or service described herein. NRC accepts no responsibility whatsoever arising in any way from any and all use and reliance on the information contained in this Listing. NRC is not undertaking to render professional or other services on behalf of any person or entity nor to perform any duty owed by any person or entity to another person or entity.